#### CUSTOMER / OWNER

ADVANCE STORAGE PRODUCTS 5702 BOLSA AVE. SUITE 150 HUNTINGTON BEACH, CA 92649

JOHN VR KRUMMELL - PRESIDENT

PHONE: 714-902-9000 FAX: 714-902-9001

#### ENGINEERING AND RACK SUPPLIER

ADVANCE STORAGE PRODUCTS 5702 BOLSA AVENUE — SUITE 150 HUNTINGTON BEACH, CALIFORNIA 92649

<u>JAMES RAHM — SALES</u>

CURTIS GILLEN - SR. PROJECT MANAGER KENNETH DAVISON - CHIEF ENGINEER

ROY LIN - ENGINEER

PHONE: 714-902-9000 FAX: 714-902-9001

### ADVANCE STORAGE PRODUCTS

#### HUNTINGTON BEACH, CA

#### **DRAWING INDEX**

SHEET	REV.	DRAWING NO.	DRAWING TITLE
0.0	_	P9XXX-0	DRAWING INDEX
1.0	_	P9XXX-1	4 DEEP PUSHBACK RACK LAYOUT PLAN VIEW
2.0	_	P9XXX-2	4 DEEP PUSHBACK RACK ELEVATIONS
3.0	_	P9XXX-3	MISCELLANEOUS INSTALLATION DETAILS
3.1	_	P9XXX-3	4 DEEP PUSHBACK INSTALLATION INSTRUCTIONS
4.0	_	P9XXX-4	BILL OF MATERIAL

## DRAWING APPROVAL APPROVED AS IS APPROVED AS NOTED NOT APPROVED SIGNATURE PRINT NAME DATE PRINT NAME

# Westminster Ave Westminster Ave Westminster Ave Westminster Ave Westminster Ave Barber City Walt 9 Hagenin St Walt 9


#### JOBSITE

ADVANCE STORAGE PRODUCTS 5702 BOLSA AVE.

SUITE 150

HUNTINGTON BEACH, CA 92649

<u>ALAN HAVEY - ENGINEER</u> PHONE: 714-902-9000 FAX: 714-902-9001



#### **GENERAL NOTES:**

- I 6. ANY FIELD CHANGES OR VARIANCES FROM SPECIFICATIONS AND DRAWINGS MUST BE AUTHORIZED IN WRITING BY ADVANCE PRIOR TO IMPLEMENTATION. SUBCONTRACTOR ASSUMES COSTS ASSOCIATED WITH CORRECTIONS OR MODIFICATION REQUIRED BECAUSE OF UNAUTHORIZED CHANGES.
- 17. RACK UPRIGHT TO BE INSTALLED WITHIN 1/2"/10"-0" FROM VERTICAL FOR THE FULL HEIGHT OF THE UPRIGHT, BOTH DOWN \$ CROSS AISLE PER RMI.
- 18. RACK ROWS SHALL BE INSTALLED WITHIN 1/2" OF BEING SQUARE TO BUILDING OVER THE FULL LENGTH OF THE AISLE.
- 19. MAXIMUM BAY GROWTH IS TO BE 1/16" PER BAY OR LESS.
- 20. WHERE ANCHOR BOLT INSTALLATION REQUIRES THE BOLT TO BE DRILLED INTO A FLOOR JOINT, AN ICC APPROVED HIGH RESIN OR EPOXY ADHESIVE
- ANCHOR IS REQUIRED.

  2 I. DISTANCE TO EXITS MAXIMUM DISTANCE OF TRAVEL FROM ANY POINT TO
  AN EXTERIOR EXIT DOOR IN A GROUP F, G \$ S TYPE BUILDING NOT EQUIPPED
  WITH AN AUTOMATIC SPRINKLER SYSTEM THROUGHOUT; SHALL NOT EXCEED
  300'-0" OR 400'-0" IN BUILDINGS THAT ARE EQUIPPED WITH AN AUTOMATIC
- 22. FIRE SPRINKLERS TO BE INSTALLED UNDER SEPARATE PERMIT
- 23. FIRE EXTINGUISHERS TO BE PROVIDED & INSTALLED BY TENANT
- 24. ALL FIELD WELDING SHALL BE ACCOMPLISHED BY A CERTIFIED WELDER. A
  CERTIFIED DEPUTY WELDING INSPECTOR SHALL BE ON SITE DURING ALL
  WELDING OPERATIONS

PPROVAL	
S NOTED	THIS DOCU INFORMATIO PRODUCTS, PARTY ACCI THEREOF ANY WAY II
DATE	ANY WAY II A THIRD PA WITHOUT E:
GS ON. IR	

8
$\mathbb{N}$
)RA
ш

INDEX

A D V A N C E STORAGE PRODUCTS

W BY: A Division of J.C.M. brighter, Inc.

W BY: A Division of J.C.M. brighter, Inc.

DATE: 0/29/09

ATE: DATE:

DATE: DATE:

DATE: DATE

**PRODUCT** 

Ш

STORAG

ADVANCE

P9XXX-0

GENERAL NOTES AND TYPICAL DETAILS. I 5. DIMENSIONS SHALL TAKE PRECEDENCE OVER SCALES ON DRAWINGS.

12. BUILDING DIMENSIONS ARE BASED ON CUSTOMER'S FLOOR PLANS.

14. NOTES AND DETAILS ON DRAWINGS SHALL TAKE PRECEDENCE OVER

1.3 IF ANY CONSTRUCTION DETAILS ARE NOT CLEAR OR ARE NOT PROVIDED

ADVANCE STORAGE PRODUCTS SHALL BE NOTIFIED, SO AS TO CLARIFY

1. SEISMIC DESIGN CRITERIA: 2006 IBC, Ss = 1.465, S1 = 0.619

7. DESIGN MEETS RMI SPECIFICATIONS - DEFLECTION CRITERIA

8. CROSS AISLE TIES ARE REQUIRED WHERE NOTED ON DRAWINGS.
9. TORQUE ALL 1/2" GRADE 5 HARDWARE TO 60 FT. LBS.

(3-1/4" MIN. - 4" MAX. EMBEDMENT IS TYPICAL. ACTUAL EMBEDMENT CALCULATED BY P.E.)

PUSHBACK:

RAILS - BLACK

IST CART - YELLOW 2ND CART - ORANGE

3RD CART - BLUE

(I) ADDTL 1/2" x 4-3/4" HILTI KWIK BOLT 3 ANCHOR PER AISLE SIDE FOOTPLATE TORQUE ANCHORS TO MFG.'S SPECIFICATIONS (INCLUDED IN ANCHOR BOX)

DESIGN OF L/180. POSTING OF PERMISSIBLE UNIT LOAD IS REQUIRED

3. WEIGHT PER PALLET: 2,500# AVG. / 2,500# MAX.

6. TYPE ANCHOR: 1/2" x 5-1/2" HILTI KWIK BOLT TZ

NOTE: USE TOUCH-UP PAINT WHEN REQUIRED.

(GALVANIZED, PAINTED OR PLASTIC)

5. SLAB 3,500 P.S.I., SOIL 1,000 P.S.F.

(2) ANCHOR(S) PER FOOTPLATE.

UNLESS OTHERWISE NOTED.

UPRIGHTS - BLUE

BEAMS - ORANGE

FRAME TIES - BLUE

OR PROVIDE THESE DETAILS.

10. COLORS: - STANDARD

LOO% UTILIZATION.

4. SLAB THICKNESS 6" MIN.
NO INTERIOR REINFORCEMENT